


BI4U-EM12WD-AP6X-H1141/3GD Inductive Sensor – For the Food Industry




Technical data

Туре	BI4U-EM12WD-AP6X-H1141/3GD		
ID no.	1634851		
Rated switching distance	4 mm		
Mounting conditions	Flush		
Secured operating distance	≤ (0.81 × Sn) mm		
Repeat accuracy	≤ 2 % of full scale		
Temperature drift	≤ ± 10 %		
	≤ ± 20 %, ≤ -25 °C , ≥ +70 °C		
Hysteresis	315 %		
Ambient temperature	-40+100 °C		
	For explosion hazardous areas see instruction leaflet		
Operating voltage	1030 VDC		
Residual ripple	≤ 10 % U _{ss}		
DC rated operational current	≤ 200 mA		
No-load current	≤ 25 mA		
Residual current	≤ 0.1 mA		
Isolation test voltage	≤ 0.5 kV		
Short-circuit protection	yes / Cyclic		
Voltage drop at I _e	≤ 1.8 V		
Wire breakage/Reverse polarity protection	yes / Complete		
Output function	3-wire, NO contact, PNP		
Insulation class			
Switching frequency	3 kHz		
Approval acc. to	ATEX test certificate TURCK Ex-10002M X		

Features


- ■Threaded barrel, M12 x 1
- Stainless steel, 1.4404
- Front cap made of liquid crystal polymer
- Factor 1 for all metals
- Resistant to magnetic fields
- ■For temperatures of -40 °C...+100 °C
- High protection class IP69K for harsh environments
- Special double-lip seal
- Protection against all common acidic and alkaline cleaning agents
- Laser engraved label, permanently legible
- DC 3-wire, 10...30 VDC
- ■NO contact, PNP output
- ■M12 x 1 male connector
- ■ATEX category II 3 G, Ex zone 2
- ■ATEX category II 3 D, Ex zone 22

Wiring diagram





Functional principle






Technical data

Device marking		
Design	Threaded barrel, M12 × 1	
Dimensions	52 mm	
Housing material	Stainless steel, 1.4404 (AISI 316L)	
Active area material	Plastic, LCP	
Connector housing	plastic, PP	
Admissible pressure on front cap	≤ 20 bar	
Max. tightening torque of housing nut	10 Nm	
Electrical connection	Connector, M12 × 1	
Vibration resistance	55 Hz (1 mm)	
Shock resistance	30 g (11 ms)	
Protection class	IP68 IP69K	
MTTF	874 years acc. to SN 29500 (Ed. 99) 40 °C	
Switching state	LED, Yellow	
Included in delivery	SC-M12/3GD	

Mounting instructions


Mounting instructions/Description





Distance D	24 mm
Distance W	3 x Sn
Distance T	3 x B
Distance S	1.5 x B
Distance G	6 x Sn
Diameter active area B	Ø 12 mm

All flush mountable uprox+ threaded barrel types are also recessed mountable. Safe operation is ensured if the sensor is screwed in by half a turn.



Accessories

MW-12

12.7


9.5

13.9

38.1


6945003

Mounting bracket for threaded barrel sensors; material: Stainless steel A2 1.4301 (AISI 304)



6901321

Mounting clamp for smooth and threaded barrel sensors; material: Polypropylene



6905309 Impact protection nut for M12x1 threaded barrel devices; material: Stainless steel A2 1.4305 (AISI 303)



Wiring accessories

Dimension drawing	Туре	ID no.	
M12x1 2/2 14	RKH4-2/TFE	6935482	Connection cable, M12 female, straight, 3-pin, stainless steel coupling nut, cable length: 2 m, jacket material: PVC, gray temperature range -25+80 °C; other cable lengths and designs available, see www.turck.com
M12×1	RKH4-2/TFG	6934384	Connection cable, M12 female, straight, 3-pin, stainless steel coupling nut, cable length: 2 m, jacket material: TPE, gray temperature range -40+105 °C; other cable lengths and designs available, see www.turck.com



Operating Instructions

Intended use

This device fulfills the directive 2014/34/EU and is suited for use in explosion hazardous areas acc. to EN 60079-0:2012/A11:2013, EN 60079-15:2010 and EN 60079-31:2014.In order to ensure correct operation to the intended purpose it is required to observe the national regulations and directives.

For use in explosion hazardous areas conform to classification

II 3 G and II 3 D (Group II, Category 3 G, electrical equipment for gaseous atmospheres and category 3 D, electrical equipment for dust atmospheres).

Marking (see device or technical data sheet)

Local admissible ambient temperature

-25...+70 °C

Installation/Commissioning

These devices may only be installed, connected and operated by trained and qualified staff. Qualified staff must have knowledge of protection classes, directives and regulations concerning electrical equipment designed for use in explosion hazardous areas. Please verify that the classification and the marking on the device comply with the actual application conditions.

Installation and mounting instructions

Avoid static charging of cables and plastic devices. Please only clean the device with a damp cloth. Do not install the device in a dust flow and avoid build-up of dust deposits on the device. The devices must be protected against strong magnetic fields. The pin configuration and the electrical specifications can be taken from the device marking or the technical data sheet. In order to avoid contamination of the device, please remove possible blanking plugs of the cable glands or connectors only shortly before inserting the cable or opening the cable socket.

Special conditions for safe operation

For devices with M12 connectors please use the supplied safety clip SC-M12/3GD.Do not disconnect the plug-in connection or cable under voltage. Please attach a warning label permanently in an appropriate fashion in close proximity to the plug-in connection with the following inscription: Nicht unter Spannung trennen / Do not separate when energized. The device must be protected against any kind of mechanical damage and degrading UV-radiation. The IP protection rating of the connectors is given only in combination with a suitable O-ringLoad voltage and operating voltage of this equipment must be supplied from power supplies with safe isolation (IEC 30 364/UL508), to ensure that the rated voltage of the equipment (24 VDC +20% = 28.8 VDC) is never exceeded by more than 40%.

Service/Maintenance

Repairs are not possible. The approval expires if the device is repaired or modified by a person other than the manufacturer. The most important data from the approval are listed.