## SIEMENS

## Data sheet

## 6AG1134-6PA01-7BU0



SIPLUS ET 200SP AI EM CT ST based on: 6ES7134-6PA01-0BU0 with conformal coating, -40...+70 °C, analog input module, AI Energy Meter CT ST, for 1A or 5A current transformer, suitable for BU type U0, channel diagnostics

					100	
Fi	a	JF)	e 5	sin	nil	ar

General information			
Product type designation	AI Energy Meter CT ST		
Firmware version			
• FW update possible	Yes		
based on	6ES7134-6PA01-0BU0		
usable BaseUnits	BU type U0		
Color code for module-specific color identification plate	CC20		
Supported power supply systems	TT, TN, IT		
Product function			
<ul> <li>Voltage measurement</li> </ul>	Yes		
<ul> <li>— without voltage transformer</li> </ul>	Yes		
— with voltage transformer	Yes		
Current measurement	Yes; max. 3 + neutral conductor		
- without current transformer	No		
- with current transformer	Yes; 1 A or 5 A current transformer		
— With Rogowski coil	No		
- With current-voltage-converter	No		
<ul> <li>Energy measurement</li> </ul>	Yes		
<ul> <li>Frequency measurement</li> </ul>	Yes		
Power measurement	Yes		
Active power measurement	Yes		
Reactive power measurement	Yes		
Power factor measurement	Yes		
Active factor measurement	Yes		
<ul> <li>Reactive power compensation</li> </ul>	Yes		
Line analysis	No		
• I&M data	Yes; I&M0 to I&M3		
Isochronous mode	No		
Engineering with			
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	see entry ID: 109746275		
Operating mode			
<ul> <li>Switching between operating modes in RUN</li> </ul>	Yes; For module version 32 I/20 Q, it is possible to dynamically switch between 25 user data variants, 23 of which are pre-defined and 2 of which can be defined by the specific user		
Cyclic measured value access	Yes		
Acyclic measured value access	Yes		
<ul> <li>Fixed measured value sets</li> </ul>	Yes		
<ul> <li>Freely definable measured value sets</li> </ul>	Yes; For cyclic and acyclic measured value access		
CiR - Configuration in RUN			
Reparameterization possible in RUN	Yes		

Calibration possible in RUN	Yes
Installation type/mounting	
Mounting position	any
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Input current	
Current consumption (rated value)	12.5 mA
Current consumption, max.	17 mA
Power loss	
Power loss, typ.	1 W; 3x 5 A input current, 3x 230 V AC
Address area	
Address space per module	
Inputs	256 byte
Outputs	20 byte
Hardware configuration	
Automatic encoding	Yes
Mechanical coding element	Yes
Type of mechanical coding element	type C
Selection of BaseUnit for connection variants	
	RU type U0
2-wire connection	BU type U0
Time of day	
Operating hours counter	
• present	Yes
Analog inputs	
Cycle time (all channels), typ.	50 ms; Time for consistent update of all measured and calculated values (cyclic und acyclic data)
Cable length	
<ul> <li>shielded, max.</li> </ul>	200 m
• unshielded, max.	200 m
unshielded, max. Analog value generation for the inputs	200 m
	200 m 2 048 kHz
Analog value generation for the inputs	
Analog value generation for the inputs Sampling frequency, max.	
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information	
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms	2 048 kHz
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms • Diagnostic alarm	2 048 kHz Yes Yes
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms   Diagnostic alarm  Limit value alarm	2 048 kHz Yes
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms   Diagnostic alarm  Limit value alarm	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms • Diagnostic alarm • Limit value alarm • Hardware interrupt	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms • Diagnostic alarm • Limit value alarm • Hardware interrupt Diagnoses • Supply voltage	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms • Diagnostic alarm • Limit value alarm • Hardware interrupt Diagnoses • Supply voltage • Hardware interrupt lost	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms    Diagnostic alarm  Limit value alarm Hardware interrupt Diagnoses  Supply voltage Hardware interrupt lost Parameter assignment error	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms    Diagnostic alarm  Limit value alarm Hardware interrupt Diagnoses  Supply voltage Hardware interrupt lost Parameter assignment error Module fault	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms    Diagnostic alarm  Limit value alarm Hardware interrupt  Diagnoses  Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms         • Diagnostic alarm         • Limit value alarm         • Hardware interrupt         Diagnoses         • Supply voltage         • Hardware interrupt lost         • Parameter assignment error         • Module fault         • Channel not available         • Overflow/underflow	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms         • Diagnostic alarm         • Limit value alarm         • Hardware interrupt         Diagnoses         • Supply voltage         • Hardware interrupt lost         • Parameter assignment error         • Module fault         • Channel not available         • Overflow/underflow         • Overload current	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs Sampling frequency, max. Interrupts/diagnostics/status information Alarms	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms         • Diagnostic alarm         • Limit value alarm         • Hardware interrupt         Diagnoses         • Supply voltage         • Hardware interrupt lost         • Parameter assignment error         • Module fault         • Channel not available         • Overflow/underflow         • Overload current         Diagnostics indication LED         • Monitoring of the supply voltage (PWR-LED)         • Channel status display	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms         • Diagnostic alarm         • Limit value alarm         • Hardware interrupt         Diagnoses         • Supply voltage         • Hardware interrupt lost         • Parameter assignment error         • Module fault         • Channel not available         • Overflow/underflow         • Overload current         Diagnostics indication LED         • Monitoring of the supply voltage (PWR-LED)         • Channel status display         • for channel diagnostics	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms         • Diagnostic alarm         • Limit value alarm         • Hardware interrupt         Diagnoses         • Supply voltage         • Hardware interrupt lost         • Parameter assignment error         • Module fault         • Channel not available         • Overflow/underflow         • Overload current         Diagnostics indication LED         • Monitoring of the supply voltage (PWR-LED)         • Channel status display         • for channel diagnostics         • for module diagnostics	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms <ul> <li>Diagnostic alarm</li> <li>Limit value alarm</li> <li>Hardware interrupt</li> </ul> Diagnoses <ul> <li>Supply voltage</li> <li>Hardware interrupt lost</li> <li>Parameter assignment error</li> <li>Module fault</li> <li>Channel not available</li> <li>Overflow/underflow</li> <li>Overload current</li> </ul> Diagnostics indication LED <ul> <li>Monitoring of the supply voltage (PWR-LED)</li> <li>Channel status display</li> <li>for channel diagnostics</li> <li>for module diagnostics</li> </ul>	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms         • Diagnostic alarm         • Limit value alarm         • Hardware interrupt         Diagnoses         • Supply voltage         • Hardware interrupt lost         • Parameter assignment error         • Module fault         • Channel not available         • Overflow/underflow         • Overload current         Diagnostics indication LED         • Monitoring of the supply voltage (PWR-LED)         • Channel diagnostics         • for channel diagnostics         • for module diagnostics         • for module diagnostics         • for module diagnostics	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms         • Diagnostic alarm         • Limit value alarm         • Hardware interrupt         Diagnoses         • Supply voltage         • Hardware interrupt lost         • Parameter assignment error         • Module fault         • Channel not available         • Overflow/underflow         • Overload current         Diagnostics indication LED         • Monitoring of the supply voltage (PWR-LED)         • Channel diagnostics         • for channel diagnostics         • for module diagnostics         • Measuring functions         • Measuring procedure for voltage measurement	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms <ul> <li>Diagnostic alarm</li> <li>Limit value alarm</li> <li>Hardware interrupt</li> </ul> Diagnoses <ul> <li>Supply voltage</li> <li>Hardware interrupt lost</li> <li>Parameter assignment error</li> <li>Module fault</li> <li>Channel not available</li> <li>Overflow/underflow</li> <li>Overload current</li> </ul> Diagnostics indication LED <ul> <li>Monitoring of the supply voltage (PWR-LED)</li> <li>Channel status display</li> <li>for channel diagnostics</li> <li>for module diagnostics</li> <li>for module diagnostics</li> <li>Measuring functions</li> <li>Measuring procedure for voltage measurement</li> <li>Measuring procedure for current measurement</li> </ul>	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms <ul> <li>Diagnostic alarm</li> <li>Limit value alarm</li> <li>Hardware interrupt</li> </ul> Diagnoses <ul> <li>Supply voltage</li> <li>Hardware interrupt lost</li> <li>Parameter assignment error</li> <li>Module fault</li> <li>Channel not available</li> <li>Overflow/underflow</li> <li>Overload current</li> </ul> Diagnostics indication LED <ul> <li>Monitoring of the supply voltage (PWR-LED)</li> <li>Channel status display</li> <li>for channel diagnostics</li> <li>for module diagnostics</li> <li>for module diagnostics</li> <li>Measuring functions</li> </ul> Measuring procedure for voltage measurement <ul> <li>Measuring procedure for current measurement</li> <li>Type of measured value acquisition</li> </ul>	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms <ul> <li>Diagnostic alarm</li> <li>Limit value alarm</li> <li>Hardware interrupt</li> </ul> Diagnoses <ul> <li>Supply voltage</li> <li>Hardware interrupt lost</li> <li>Parameter assignment error</li> <li>Module fault</li> <li>Channel not available</li> <li>Overflow/underflow</li> <li>Overload current</li> </ul> Diagnostics indication LED <ul> <li>Monitoring of the supply voltage (PWR-LED)</li> <li>Channel status display</li> <li>for channel diagnostics</li> <li>for module diagnostics</li> <li>for module diagnostics</li> <li>Measuring functions</li> </ul> Measuring procedure for voltage measurement <ul> <li>Measuring procedure for current measurement</li> <li>Type of measured value acquisition</li> <li>Curve shape of voltage</li> </ul>	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms <ul> <li>Diagnostic alarm</li> <li>Limit value alarm</li> <li>Hardware interrupt</li> </ul> Diagnoses <ul> <li>Supply voltage</li> <li>Hardware interrupt lost</li> <li>Parameter assignment error</li> <li>Module fault</li> <li>Channel not available</li> <li>Overflow/underflow</li> <li>Overload current</li> </ul> Diagnostics indication LED <ul> <li>Monitoring of the supply voltage (PWR-LED)</li> <li>Channel status display</li> <li>for channel diagnostics</li> <li>for channel diagnostics</li> <li>for channel diagnostics</li> <li>for module diagnostics</li> </ul> Integrated Functions         Measuring procedure for voltage measurement <ul> <li>Measuring procedure for current measurement</li> <li>Type of measured value acquisition</li> <li>Curve shape of voltage</li> <li>Buffering of measured variables</li> </ul>	2 048 kHz Yes Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes Yes
Analog value generation for the inputs         Sampling frequency, max.         Interrupts/diagnostics/status information         Alarms <ul> <li>Diagnostic alarm</li> <li>Limit value alarm</li> <li>Hardware interrupt</li> </ul> Diagnoses <ul> <li>Supply voltage</li> <li>Hardware interrupt lost</li> <li>Parameter assignment error</li> <li>Module fault</li> <li>Channel not available</li> <li>Overflow/underflow</li> <li>Overload current</li> </ul> Diagnostics indication LED <ul> <li>Monitoring of the supply voltage (PWR-LED)</li> <li>Channel status display</li> <li>for channel diagnostics</li> <li>for module diagnostics</li> <li>for module diagnostics</li> <li>Measuring functions</li> </ul> Measuring procedure for voltage measurement <ul> <li>Measuring procedure for current measurement</li> <li>Type of measured value acquisition</li> <li>Curve shape of voltage</li> </ul>	2 048 kHz Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value) Yes Yes Yes Yes Yes Yes Yes Yes

Measuring range	
— Frequency measurement, min.	40 Hz
<ul> <li>Frequency measurement, max.</li> </ul>	70 Hz
Measuring inputs for voltage	10112
Measurable line voltage between phase and neutral conductor	277 V
<ul> <li>Measurable line voltage between the line conductors</li> </ul>	480 V
<ul> <li>Measurable line voltage between phase and neutral conductor, min.</li> </ul>	3 V
<ul> <li>Measurable line voltage between phase and neutral conductor, max.</li> </ul>	300 V
<ul> <li>Measurable line voltage between the line conductors, min.</li> </ul>	6 V
<ul> <li>Measurable line voltage between the line conductors, max.</li> </ul>	519 V
<ul> <li>Internal resistance line conductor and neutral conductor</li> </ul>	1.5 ΜΩ
<ul> <li>Power consumption per phase</li> </ul>	60 mW; 300 V AC
<ul> <li>Impulse voltage resistance 1,2/50µs</li> </ul>	2.5 kV
<ul> <li>Measurement category for voltage measurement in accordance with IEC 61010-2-030</li> </ul>	CAT II
Measuring inputs for current	
- measurable relative current (AC), min.	1 %; Relative to measuring range; 1 A, 5 A
- measurable relative current (AC), max.	100 %; Relative to the secondary rated current 5 A
- Continuous current with AC, maximum permissible	5 A
<ul> <li>Apparent power consumption per phase for measuring range 5 A</li> </ul>	0.6 VA
<ul> <li>Rated value short-time withstand current restricted to 1 s</li> </ul>	100 A
<ul> <li>Input resistance measuring range 0 to 5 A</li> </ul>	25 mΩ; At the terminal
— Surge strength	10 A; for 1 minute
— Zero point suppression	0 20%, referred to the nominal current
Accuracy class according to IEC 61557-12	
— Measured variable voltage	0,2
— Measured variable current	0,2
— Measured variable apparent power	0.5
Measured variable active power	0.5
Measured variable reactive power	1
— Measured variable power factor	0.5
— Measured variable active energy	0.5
Measured variable reactive energy	1
Measured variable neutral current	0,2
— Measured variable phase angle	±0.5°; not covered by IEC 61557-12
— Measured variable frequency	0.05; only valid for the permissible voltage measuring range
Potential separation	
Potential separation channels	
between the channels	No
between the channels and backplane bus	Yes
Between the channels and load voltage L+ Isolation	Yes; Including FE
Isolation tested with	Between channels and backplane bus, 24 V supply: Routine test, 1 920 V AC, 2 s; between backplane bus and 24 V supply: Type test, 707 V DC
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	-40 °C; = Tmin (incl. condensation/frost)
horizontal installation, max.	$70 ^{\circ}\text{C}$ ; = Tmax
vertical installation, min.	-40 °C; = Tmin
vertical installation, max.	50 °C; = Tmax
Altitude during operation relating to sea level	
Installation altitude above sea level, max.	3 000 m; Restrictions for installation altitudes > 2 000 m, see manual
Relative humidity	
• With condensation, tested in accordance with IEC 60068- 2-38, max.	100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation

Resistance				
Coolants and lubricants				
<ul> <li>— Resistant to commercially available coolants and lubricants</li> </ul>	Yes; Incl. diesel and oil droplets in the air			
Use in stationary industrial systems				
<ul> <li>— to biologically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request			
<ul> <li>— to chemically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *			
<ul> <li>— to mechanically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3S4 incl. sand, dust, *			
<ul> <li>— Against mechanical environmental conditions acc. to EN 60721-3-3</li> </ul>	Yes; Class 3M8 using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00- 0AA0//6AG1193-6AB00-0AA0)			
Use on ships/at sea				
<ul> <li>— to biologically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6B2 mold, fungal and dry rot spores (excluding fauna)			
<ul> <li>— to chemically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *			
<ul> <li>— to mechanically active substances according to EN 60721-3-6</li> </ul>	Yes; Class 6S3 incl. sand, dust; *			
<ul> <li>— Against mechanical environmental conditions acc. to EN 60721-3-6</li> </ul>	Yes; class 6M4 using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0/6AG1193-6AB00-0AA0)			
Usage in industrial process technology				
<ul> <li>— Against chemically active substances acc. to EN 60654-4</li> </ul>	Yes; Class 3 (excluding trichlorethylene)			
<ul> <li>Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04</li> </ul>	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)			
Remark				
<ul> <li>— Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04</li> </ul>	* The supplied plug covers must remain in place over the unused interfaces during operation!			
Conformal coating				
<ul> <li>Coatings for printed circuit board assemblies acc. to EN 61086</li> </ul>	Yes; Class 2 for high reliability			
<ul> <li>Protection against fouling acc. to EN 60664-3</li> </ul>	Yes; Type 1 protection			
<ul> <li>Military testing according to MIL-I-46058C, Amendment 7</li> </ul>	Yes; Discoloration of coating possible during service life			
<ul> <li>Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC- CC-830A</li> </ul>	Yes; Conformal coating, Class A			
mensions				
Vidth	20 mm			
Height	73 mm			
Depth	58 mm	58 mm		
eights				
Neight, approx.	45 g			
her				
Data for selecting a voltage transformer				
<ul> <li>Secondary side, max.</li> </ul>	300 V			
Data for selecting a current transformer				
• Burden power current transformer x/1A, min.	As a function of cable length an	d cross section, see device	ce manual	
Burden power current transformer x/5A, min.	As a function of cable length an	d cross section, see devic	ce manual	
assifications				
		Version	Classification	
	eClass	14	27-24-26-01	
	eClass	12	27-24-26-01	
	eClass	9.1	27-24-26-01	
	eClass	9	27-24-26-01	
	eClass	8	27-24-26-01	

eClass

eClass

ETIM

ETIM

27-24-26-01

27-24-26-01 EC001596

EC001596

7.1

6

9

8



last modified:

11/26/2024 🖸