## **SIEMENS**

## **Data sheet**

6ES7511-1FL03-0AB0





SIMATIC S7-1500F, CPU 1511F-1 PN, central processing unit with work memory 450 KB for program and 1.5 MB for data, 1st interface: PROFINET IRT with 2-port switch, 25 ns bit performance, SIMATIC Memory Card required - - approvals and certificates according to entry 109815653 at support.industry.siemens.com to be considered! - -

General information	
Product type designation	CPU 1511F-1 PN
HW functional status	FS03
Firmware version	V3.1
<ul> <li>FW update possible</li> </ul>	Yes
Product function	
● I&M data	Yes; I&M0 to I&M3
• Isochronous mode	Yes; Distributed and central; with minimum OB $6x$ cycle of $500~\mu s$ (distributed) and $1~ms$ (central)
SysLog	Yes
Engineering with	
STEP 7 TIA Portal configurable/integrated from version	V19 (FW V3.1) / V18 (FW V3.0) or higher; with older TIA Portal versions configurable as 6ES7511-1FK02-0AB0
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	3.45 cm
Control elements	
Number of keys	8
Mode buttons	2
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	0.56 A
Current consumption, max.	0.9 A
Inrush current, max.	1.15 A; Rated value
l²t	0.5 A²·s
Power	
Infeed power to the backplane bus	10 W
Power consumption from the backplane bus (balanced)	5.5 W
Power loss	

Power loss, typ.	3.4 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	450 kbyte
• integrated (for data)	1.5 Mbyte
Load memory	
Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	
• maintenance-free	Yes
CPU processing times	
for bit operations, typ.	25 ns
for word operations, typ.	32 ns
for fixed point arithmetic, typ.	42 ns
for floating point arithmetic, typ.	170 ns
CPU-blocks	
Number of elements (total)	4 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1.5 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	450 kbyte
FC FC	
Number range	0 65 535
• Size, max.	450 kbyte
OB	
• Size, max.	450 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	100
<ul> <li>Number of time alarm OBs</li> </ul>	20
<ul> <li>Number of delay alarm OBs</li> </ul>	20
<ul> <li>Number of cyclic interrupt OBs</li> </ul>	20; With minimum OB 3x cycle of 250 μs
<ul> <li>Number of process alarm OBs</li> </ul>	50
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3
<ul> <li>Number of isochronous mode OBs</li> </ul>	2
<ul> <li>Number of technology synchronous alarm OBs</li> </ul>	2
<ul> <li>Number of startup OBs</li> </ul>	100
<ul> <li>Number of asynchronous error OBs</li> </ul>	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	2049
Number  Petantivity	2 048
Retentivity	Von
— adjustable  IEC counter	Yes
Number	Any (only limited by the main memory)
Retentivity	Any (only limited by the main memory)
— adjustable	Yes
— aujustable S7 times	
Number	2 048
Retentivity	20.0
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	, , , , , , , , , , , , , , , , , , , ,
— adjustable	Yes
•	

Data areas and their retentivity		
Retentive data area (incl. timers, counters, flags), max.	256 kbyte; in total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 216 KB	
Extended retentive data area (incl. timers, counters, flags), max.	1.5 Mbyte; When using PS 6 0W 24/48/60 V DC HF	
Flag		
• Size, max.	16 kbyte	
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte	
Data blocks		
<ul> <li>Retentivity adjustable</li> </ul>	Yes	
Retentivity preset	No	
Local data		
<ul> <li>per priority class, max.</li> </ul>	64 kbyte; max. 16 KB per block	
Address area		
Number of IO modules	2 048; max. number of modules / submodules	
I/O address area		
• Inputs	32 kbyte; All inputs are in the process image	
Outputs	32 kbyte; All outputs are in the process image	
per integrated IO subsystem	, , , , , , , , , , , , , , , , , , , ,	
— Inputs (volume)	8 kbyte	
— Outputs (volume)	8 kbyte	
per CM/CP		
— Inputs (volume)	8 kbyte	
Outputs (volume)	8 kbyte	
Subprocess images	·,	
Number of subprocess images, max.	32	
Hardware configuration	VL	
	20. A distributed I/O system is showestering durational return by the intermedian of	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)	
Number of DP masters		
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total	
Number of IO Controllers		
• integrated	1	
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be	
	inserted in total	
Rack		
<ul> <li>Modules per rack, max.</li> </ul>	32; CPU + 31 modules	
Number of lines, max.	1	
PtP CM		
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots	
Time of day		
Clock		
• Type	Hardware clock	
Backup time	6 wk; At 40 °C ambient temperature, typically	
Deviation per day, max.	10 s; Typ.: 2 s	
Operating hours counter		
Number	16	
Clock synchronization		
Clock synchronization • supported	Yes	
•	Yes Yes; Via CM DP module	
• supported		
supported     to DP, master	Yes; Via CM DP module	
<ul><li>supported</li><li>to DP, master</li><li>on DP, device</li></ul>	Yes; Via CM DP module Yes; Via CM DP module	
<ul> <li>supported</li> <li>to DP, master</li> <li>on DP, device</li> <li>in AS, master</li> </ul>	Yes; Via CM DP module Yes; Via CM DP module Yes	
<ul> <li>supported</li> <li>to DP, master</li> <li>on DP, device</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul>	Yes; Via CM DP module Yes; Via CM DP module Yes Yes	
<ul> <li>supported</li> <li>to DP, master</li> <li>on DP, device</li> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul>	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes	
supported     to DP, master     on DP, device     in AS, master     in AS, device     on Ethernet via NTP  nterfaces  Number of PROFINET interfaces	Yes; Via CM DP module Yes; Via CM DP module Yes Yes	
supported     to DP, master     on DP, device     in AS, master     in AS, device     on Ethernet via NTP  nterfaces  Number of PROFINET interfaces  I. Interface	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes	
supported     to DP, master     on DP, device     in AS, master     in AS, device     on Ethernet via NTP	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes	

integrated switch	Yes
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
<ul> <li>SIMATIC communication</li> </ul>	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	
Services	
— Isochronous mode	Yes
Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
— Prioritized startup	Yes; Max. 32 PROFINET devices
Number of connectable IO Devices, max.	128; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
Number of connectable IO Devices for RT, max.	128
— of which in line, max.	128
Number of IO Devices that can be simultaneously activated/deactivated, max.	8; in total across all interfaces
Number of IO Devices per tool, max.  Underline times.	The minimum value of the undete time also depends on communication share
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
— PROFINET Security Class	1
Update time for IRT	
— for send cycle of 250 μs	250 µs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum
	update time of 500 μs of the isochronous OB is decisive
— for send cycle of 500 μs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)
Update time for RT	
— for send cycle of 250 µs	250 µs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	No
— Isochronous mode — IRT	No Yes
— PROFlenergy	Yes; per user program
Shared device  Number of IO Controllers with shared device, may	Yes 4
Number of IO Controllers with shared device, max.	
activation/deactivation of I-devices  Asset management record.	Yes; per user program
Asset management record  PROFINET Security Class	Yes; per user program SNMP Configuration and DCP Read Only
— PROFINET Security Class	Oranii Conniguration and DOP Read Only
Interface types  RJ 45 (Ethernet)	
· /	Yes
100 Mbps     Autonogotiation	Yes
<ul><li>Autonegotiation</li><li>Autocrossing</li></ul>	Yes
Autocrossing     Industrial Ethernet status LED	Yes
Protocols	
PROFIsafe	Yes; V2.4 / V2.6
Number of connections	100, 12.77 12.0
Number of connections	

<ul> <li>Number of connections, max.</li> </ul>	128; via integrated interfaces of the CPU and connected CPs / CMs
<ul> <li>Number of connections reserved for ES/HMI/web</li> </ul>	10
<ul> <li>Number of connections via integrated interfaces</li> </ul>	88
Number of S7 routing paths	16
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— Media redundancy	only via 1st interface (X1)
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager;
	MRP Client
<ul> <li>MRP interconnection, supported</li> </ul>	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
<ul> <li>Switchover time on line break, typ.</li> </ul>	200 ms; For MRP, bumpless for MRPD
— Number of stations in the ring, max.	50
SIMATIC communication	
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
• S7 routing	Yes
Data record routing	Yes
S7 communication, as server	Yes
S7 communication, as client	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; max. 78 multicast circuits
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
• web API	
Number of sessions, max.	50
— number of simultaneous HTTP calls, max.	4
— HTTP request body, max.	131 072 byte
OPC UA	
Runtime license required	Yes; "Small" license required
OPC UA Client	Yes; Data Access (registered Read/Write), Method Call
Application authentication	Yes
<ul><li>— Security policies</li></ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
Number of connections, max.	4
Number of recimectoris, max.      Number of nodes of the client interfaces, recommended max.	1 000
— Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_U max.	300
Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max.	20
Number of elements for one call of OPC_UA_MethodGetHandleList, max.	100
Number of simultaneous calls of the client instructions for session management, per connection, max.	1

	5
<ul> <li>Number of simultaneous calls of the client instructions for data access, per connection, max.</li> </ul>	
<ul> <li>Number of registerable nodes, max.</li> </ul>	5 000
<ul> <li>Number of registerable method calls of OPC_UA_MethodCall, max.</li> </ul>	100
<ul> <li>Number of inputs/outputs when calling OPC_UA_MethodCall, max.</li> </ul>	20
OPC UA Server	Yes; Data Access (Read, Write, Subscribe), Method Call, Alarms & Condition (A&C), Custom Address Space
<ul> <li>Application authentication</li> </ul>	Yes
— Security policies	available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256, Aes128Sha256RsaOaep, Aes256Sha256RsaPss
<ul> <li>User authentication</li> </ul>	"anonymous" or by user name & password
<ul> <li>— GDS support (certificate management)</li> </ul>	Yes
— Number of sessions, max.	32
<ul> <li>Number of accessible variables, max.</li> </ul>	50 000
<ul> <li>Number of registerable nodes, max.</li> </ul>	10 000
<ul> <li>Number of subscriptions per session, max.</li> </ul>	50
<ul><li>— Sampling interval, min.</li></ul>	100 ms
— Publishing interval, min.	200 ms
<ul><li>Number of server methods, max.</li></ul>	20
<ul> <li>Number of inputs/outputs per server method, max.</li> </ul>	20
<ul> <li>Number of monitored items, recommended max.</li> </ul>	4 000; for 1 s sampling interval and 1 s send interval
<ul> <li>Number of server interfaces, max.</li> </ul>	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
<ul> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	15 000
<ul> <li>Alarms and Conditions</li> </ul>	Yes
<ul> <li>Number of program alarms</li> </ul>	100
<ul> <li>Number of alarms for system diagnostics</li> </ul>	50
Further protocols	
• MODBUS	Yes; MODBUS TCP
7 message functions	
Number of login stations for message functions, max.	32
number of subscriptions, max.	250
number of tags/attributes for subscriptions, max.	2 000
Program alarms	Yes
Number of configurable program messages, max.	5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
	F 000
Number of loadable program messages in RUN, max.	5 000
Number of loadable program messages in RUN, max.  Number of simultaneously active program alarms	5 000
	600
Number of simultaneously active program alarms	
Number of simultaneously active program alarms  • Number of program alarms	600
Number of simultaneously active program alarms  • Number of program alarms  • Number of alarms for system diagnostics	600 100
Number of simultaneously active program alarms  • Number of program alarms  • Number of alarms for system diagnostics  • Number of alarms for motion technology objects	600 100
Number of simultaneously active program alarms  • Number of program alarms  • Number of alarms for system diagnostics  • Number of alarms for motion technology objects  est commissioning functions	600 100 160
Number of simultaneously active program alarms  • Number of program alarms  • Number of alarms for system diagnostics  • Number of alarms for motion technology objects  [est commissioning functions  Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Number of simultaneously active program alarms  • Number of program alarms  • Number of alarms for system diagnostics  • Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block	600 100 160  Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
Number of simultaneously active program alarms  • Number of program alarms  • Number of alarms for system diagnostics  • Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints	600 100 160  Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes
Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Cest commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling	600 100 160  Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8
Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control	600 100 160  Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes
Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control  Status/control variable	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times,
Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control  Status/control variable  Variables	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times,
Number of simultaneously active program alarms  Number of program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control  Status/control variable  Variables  Number of variables, max.	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Set commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control  Status/control  Status/control variable  Variables  Number of variables, max.  — of which status variables, max.	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job
Number of simultaneously active program alarms  Number of program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  iest commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control  Status/control  Status/control variable  Variables  Number of variables, max.  — of which status variables, max.  — of which control variables, max.	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job
Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control  Status/control  Status/control variable  Variables  Number of variables, max.  — of which status variables, max.  — of which control variables, max.  Forcing	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job 200; per job
Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing  Forcing  Forcing, variables, max.	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job Yes; without fail-safe
Number of simultaneously active program alarms  Number of program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Sest commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control  Status/control  Status/control variable  Variables  Number of variables, max.  — of which status variables, max.  — of which control variables, max.  Forcing  Forcing  Forcing  Forcing, variables	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
Number of simultaneously active program alarms  Number of program alarms  Number of alarms for system diagnostics  Number of alarms for motion technology objects  Test commissioning functions  Joint commission (Team Engineering)  Status block  Single step  Number of breakpoints  Profiling  Status/control  Status/control variable  Variables  Number of variables, max.  of which status variables, max.  of which control variables, max.  Forcing  Forcing  Forcing  Forcing, variables, max.	Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters  200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)

a Number of entries	1 000
Number of entries, max.  of which powerful proof.	1 000
— of which powerfail-proof	500
Traces	4
Number of configurable Traces     Moment size per trace, max.	4 F12 khyto
Memory size per trace, max.  Interrupts/diagnostics/ctatus information.	512 kbyte
Interrupts/diagnostics/status information	
Diagnostics indication LED	Voc
RUN/STOP LED     FREDOR LED	Yes
• ERROR LED	Yes
MAINT LED     STOP ACTIVE LED	Yes
STOP ACTIVE LED     Connection display LINK TY/DY	Yes
Connection display LINK TX/RX     Supported technology objects	Yes
	Vac Note: The number of technology chiects offerts the guals time of the DLC
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
<ul> <li>Number of available Motion Control resources for technology objects</li> </ul>	1 120
<ul> <li>Required Motion Control resources</li> </ul>	
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
Positioning axis	
<ul> <li>Number of positioning axes at motion control cycle of 4 ms (typical value)</li> </ul>	11
<ul> <li>Number of positioning axes at motion control cycle of 8 ms (typical value)</li> </ul>	14
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Siemens Eco Profile (SEP)	Siemens EcoTech
Ecological footprint	
environmental product declaration	Yes
Global warming potential	
<ul><li>— global warming potential, (total) [CO2 eq]</li></ul>	80.1 kg
<ul><li>— global warming potential, (during production) [CO2 eq]</li></ul>	23.8 kg
— global warming potential, (during operation) [CO2 eq]	57.4 kg
— global warming potential, (after end of life cycle) [CO2 eq]  Lichard after place policycles in pofety reads.	-1.29 kg
Highest safety class achievable in safety mode	Dia
Performance level according to ISO 13849-1     SIL coacts IFO 04509	PLe
SIL acc. to IEC 61508  Probability of failure (for convice life of 20 years and rangin time)	SIL 3
Probability of failure (for service life of 20 years and repair time  — Low demand mode: PFDavg in accordance with  SIL3	< 2.00E-05
High demand/continuous mode: PFH in accordance with SIL3	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	-30 °C; No condensation
horizontal installation, max.	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
• vertical installation, min.	-30 °C; No condensation
• vertical installation, max.	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off

Ambient temperature during storage/transportation	40 °C			
• min.	-40 °C			
• max.	70 °C			
Altitude during operation relating to sea level				
Installation altitude above sea level, max.	5 000 m; Restrictions for insta	allation altitudes > 2 000 r	n, see manual	
onfiguration / header				
configuration / programming / header				
Programming language				
— LAD	Yes; incl. failsafe			
— FBD	·	Yes; incl. failsafe		
— STL	Yes	Yes		
— SCL	Yes	Yes		
— CFC	Yes; either CFC or failsafe fu	Yes; either CFC or failsafe functionality		
— GRAPH	Yes	Yes		
Know-how protection				
<ul> <li>User program protection/password protection</li> </ul>	Yes			
<ul> <li>Copy protection</li> </ul>	Yes			
Block protection	Yes			
Access protection				
<ul> <li>protection of confidential configuration data</li> </ul>	Yes			
<ul> <li>Password for display</li> </ul>	Yes			
Protection level: Write protection	Yes			
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes			
<ul> <li>Protection level: Write protection for Failsafe</li> </ul>	Yes			
<ul> <li>Protection level: Complete protection</li> </ul>	Yes			
User administration	Yes; device-wide			
programming / cycle time monitoring / header				
lower limit	adjustable minimum cycle time			
• upper limit	adjustable maximum cycle time			
imensions				
Width	35 mm			
Height	147 mm			
Depth	129 mm			
/eights				
Weight, approx.	336 g			
lassifications				
		Version	Classification	
	eClass	14	27-24-22-07	
	eClass	12	27-24-22-07	
	21		07.04.05.5-	

	Version	Classification
eClass	14	27-24-22-07
eClass	12	27-24-22-07
eClass	9.1	27-24-22-07
eClass	9	27-24-22-07
eClass	8	27-24-22-07
eClass	7.1	27-24-22-07
eClass	6	27-24-22-07
ETIM	9	EC000236
ETIM	8	EC000236
ETIM	7	EC000236
IDEA	4	3565
UNSPSC	15	32-15-17-05

## Approvals / Certificates

**General Product Approval** 

Manufacturer Declaration







Miscellaneous



<u>KC</u>



<u>FM</u>



<u>FM</u>



For use in hazardous locations

**Functional Saftey** 

Marine / Shipping

Type Examination Cer-tificate



Miscellaneous



Type Examination Cer-tificate



Marine / Shipping





NK / Nippon Kaiji Ky-okai



CCS (China Classification Society)



other

Environment

**PROFINET** 







last modified:

12/8/2024

