# **SIEMENS**

### **Data sheet**

## 6ES7134-6PA01-0BU0



SIMATIC ET 200SP, analog input module, AI Energy Meter CT ST, for 1A or 5A current transformer, suitable for BU type U0, channel diagnostics

General information		
Product type designation	Al Energy Meter CT ST	
Firmware version	V8.0	
<ul> <li>FW update possible</li> </ul>	Yes	
usable BaseUnits	BU type U0	
Color code for module-specific color identification plate	CC20	
Supported power supply systems	TT, TN, IT	
Product function		
Voltage measurement	Yes	
<ul> <li>— without voltage transformer</li> </ul>	Yes	
— with voltage transformer	Yes	
Current measurement	Yes; max. 3 + neutral conductor	
<ul> <li>— without current transformer</li> </ul>	No	
— with current transformer	Yes; 1 A or 5 A current transformer	
— With Rogowski coil	No	
With current-voltage-converter	No	
Energy measurement	Yes	
Frequency measurement	Yes	
Power measurement	Yes	
Active power measurement	Yes	
Reactive power measurement	Yes	
Power factor measurement	Yes	
Active factor measurement	Yes	
Reactive power compensation	Yes	
Line analysis	No	
● I&M data	Yes; I&M0 to I&M3	
<ul> <li>Isochronous mode</li> </ul>	No	
Engineering with		
STEP 7 TIA Portal configurable/integrated from version	STEP 7 V16 or higher with HSP	
STEP 7 configurable/integrated from version	Configurable via GSD file	
<ul> <li>PROFIBUS from GSD version/GSD revision</li> </ul>	One GSD file each, Revision 3 and 5 and higher	
<ul> <li>PROFINET from GSD version/GSD revision</li> </ul>	V2.3	
Operating mode		
Switching between operating modes in RUN	Yes; For module version 32 I/20 Q, it is possible to dynamically switch between 25 user data variants, 23 of which are pre-defined and 2 of which can be defined by the specific user	
Cyclic measured value access	Yes	
Acyclic measured value access	Yes	
Fixed measured value sets	Yes	
Freely definable measured value sets	Yes; For cyclic and acyclic measured value access	
CiR - Configuration in RUN		

Reparameterization possible in RUN	Yes
Calibration possible in RUN	Yes
Installation type/mounting	
Mounting position	any
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Input current	
Current consumption (rated value)	12.5 mA
Current consumption, max.	17 mA
Power loss	
Power loss, typ.	1 W; 3x 5 A input current, 3x 230 V AC
Address area	
Address space per module	
• Inputs	256 byte
Outputs	20 byte
Hardware configuration	,
Automatic encoding	Yes
Mechanical coding element	Yes
Type of mechanical coding element	type C
Selection of BaseUnit for connection variants	7.7
2-wire connection	BU type U0
Time of day	20 960 00
Operating hours counter	
• present	Yes
Analog inputs	163
	E0 may Time for consistent undete of all measured and calculated values (evaling
Cycle time (all channels), typ.	50 ms; Time for consistent update of all measured and calculated values (cyclic und acyclic data)
Cable length	
• shielded, max.	200 m
• unshielded, max.	200 m
Analog value generation for the inpute	
Analog value generation for the inputs	
Analog value generation for the inputs  Sampling frequency, max.	2 048 kHz
Sampling frequency, max.	2 048 kHz
Sampling frequency, max. Interrupts/diagnostics/status information	2 048 kHz
Sampling frequency, max. Interrupts/diagnostics/status information Alarms	
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm	Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm	Yes Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm	Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm  • Limit value alarm  • Hardware interrupt	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm • Limit value alarm • Hardware interrupt  Diagnoses	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  • Diagnostic alarm • Limit value alarm • Hardware interrupt  Diagnoses • Supply voltage • Hardware interrupt lost	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses  Supply voltage Hardware interrupt lost Parameter assignment error Module fault	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses  Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED	Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses  Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED Monitoring of the supply voltage (PWR-LED)	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED Monitoring of the supply voltage (PWR-LED) Channel status display	Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED Monitoring of the supply voltage (PWR-LED) Channel status display for channel diagnostics for module diagnostics	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED Monitoring of the supply voltage (PWR-LED) Channel status display for channel diagnostics for module diagnostics	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED Monitoring of the supply voltage (PWR-LED) Channel status display for channel diagnostics for module diagnostics Integrated Functions  Measuring functions	Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED Monitoring of the supply voltage (PWR-LED) Channel status display for channel diagnostics for module diagnostics for module diagnostics Integrated Functions  Measuring functions  Measuring procedure for voltage measurement	Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED Monitoring of the supply voltage (PWR-LED) Channel status display for channel diagnostics for module diagnostics for module diagnostics Integrated Functions  Measuring procedure for voltage measurement Measuring procedure for current measurement	Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED Monitoring of the supply voltage (PWR-LED) Channel status display for channel diagnostics for module diagnostics for module diagnostics  Integrated Functions  Measuring procedure for voltage measurement Measuring procedure for current measurement Type of measured value acquisition	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED  Monitoring of the supply voltage (PWR-LED) Channel status display for channel diagnostics for module diagnostics for module diagnostics  Integrated Functions  Measuring procedure for voltage measurement Measuring procedure for current measurement Type of measured value acquisition Curve shape of voltage	Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Sampling frequency, max.  Interrupts/diagnostics/status information  Alarms  Diagnostic alarm Limit value alarm Hardware interrupt  Diagnoses Supply voltage Hardware interrupt lost Parameter assignment error Module fault Channel not available Overflow/underflow Overload current  Diagnostics indication LED Monitoring of the supply voltage (PWR-LED) Channel status display for channel diagnostics for module diagnostics for module diagnostics  Integrated Functions  Measuring procedure for voltage measurement Measuring procedure for current measurement Type of measured value acquisition	Yes Yes Yes; Monitoring of up to 16 freely selectable process values (exceeding or undershooting of value)  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye

Bandwidth of measured value acquisition	3.2 kHz; Harmonics: 63 / 50 Hz, 52 / 60 Hz		
Bandwidth of measured value acquisition     Measuring range	3.2 KHZ; Harmonics: 63 / 50 Hz, 52 / 60 Hz		
Frequency measurement, min.	40 Hz		
Frequency measurement, max.	70 Hz		
Measuring inputs for voltage			
Measurable line voltage between phase and neutral conductor	277 V 480 V		
Measurable line voltage between the line conductors			
Measurable line voltage between phase and neutral conductor, min.	3 V		
Measurable line voltage between phase and neutral conductor, max.	300 V		
Measurable line voltage between the line conductors, min.	6 V		
<ul> <li>Measurable line voltage between the line conductors, max.</li> </ul>	519 V		
<ul> <li>Internal resistance line conductor and neutral conductor</li> </ul>	1.5 ΜΩ		
<ul> <li>Power consumption per phase</li> </ul>	60 mW; 300 V AC		
<ul> <li>Impulse voltage resistance 1,2/50μs</li> </ul>	2.5 kV		
<ul> <li>Measurement category for voltage measurement in accordance with IEC 61010-2-030</li> </ul>	CAT II		
Measuring inputs for current			
— measurable relative current (AC), min.	1 %; Relative to measuring range; 1 A, 5 A		
<ul> <li>measurable relative current (AC), max.</li> </ul>	100 %; Relative to the secondary rated current 5 A		
Continuous current with AC, maximum permissible	5 A		
<ul> <li>Apparent power consumption per phase for measuring range 5 A</li> </ul>	0.6 VA		
<ul> <li>Rated value short-time withstand current restricted to 1 s</li> </ul>	100 A		
— Input resistance measuring range 0 to 5 A	25 mΩ; At the terminal		
— Surge strength	10 A; for 1 minute		
— Zero point suppression	0 20%, referred to the nominal current		
Accuracy class according to IEC 61557-12	0.2		
Measured variable current	0,2		
Measured variable current	0,2		
Measured variable apparent power	0.5		
Measured variable active power	0.5		
Measured variable reactive power	1		
Measured variable power factor	0.5		
Measured variable active energy	0.5		
Measured variable reactive energy	1		
Measured variable neutral current	0,2		
Measured variable phase angle	±0.5°; not covered by IEC 61557-12		
— Measured variable frequency	0.05; only valid for the permissible voltage measuring range		
Potential separation			
Potential separation channels			
between the channels	No		
between the channels and backplane bus	Yes		
Between the channels and load voltage L+	Yes; Including FE		
Isolation			
Isolation tested with	Between channels and backplane bus, 24 V supply: Routine test, 1 920 V AC, 2 s; between backplane bus and 24 V supply: Type test, 707 V DC		
Ambient conditions			
Ambient temperature during operation	20.00		
horizontal installation, min.	-30 °C		
	• horizontal installation, max. 60 °C		
vertical installation, min.	-30 °C		
vertical installation, max.	50 °C		
Altitude during operation relating to sea level			
Installation altitude above sea level, max.	3 000 m; Restrictions for installation altitudes > 2 000 m, see manual		
Dimensions			
Width	20 mm		

11.11	70	
Height	73 mm 58 mm	
Depth		
Weights		
Weight, approx.	45 g	
Other		
Data for selecting a voltage transformer		
Secondary side, max.	300 V	
Data for selecting a current transformer		
<ul> <li>Burden power current transformer x/1A, min.</li> </ul>	As a function of cable length and cross section, see device manual	
<ul> <li>Burden power current transformer x/5A, min.</li> </ul>	As a function of cable length and cross section, see device manual	
Classifications		

	Version	Classification
eClass	14	27-24-26-01
eClass	12	27-24-26-01
eClass	9.1	27-24-26-01
eClass	9	27-24-26-01
eClass	8	27-24-26-01
eClass	7.1	27-24-26-01
eClass	6	27-24-26-01
ETIM	9	EC001596
ETIM	8	EC001596
ETIM	7	EC001596
IDEA	4	3562
UNSPSC	15	32-15-17-05

### Approvals / Certificates

#### **General Product Approval**





Manufacturer Declara-tion



<u>KC</u>



For use in hazardous locations

### Marine / Shipping



<u>FM</u>









Marine / Shipping

NK / Nippon Kaiji Ky-<u>okai</u>





CCS (China Classification Society)



last modified:

5/22/2024

